



City of Camarillo

601 Carmen Drive

Camarillo, Ca 93010

(805) 388-5395 • Fax (805) 388-5393

Email: bldgsafe@ci.camarillo.ca.us

HVAC REPLACEMENT REQUIREMENTS

1. All piping, chases, electrical boxes added to exterior of house must be painted to match existing house.
2. Primary condensate shall empty into an approved plumbing fixture. If not possible a sump using a minimum size 2 gallon bucket with pea gravel may be substituted.
3. Condenser shall be secured to base and all conduits must be properly strapped in place.
4. Condenser placement must meet Community Development setback standards. (Zone Clearance)
5. Pumps for primary condensates shall not be placed in cold air return.
6. When replacing existing ductwork, all conditions for new installation will apply. (Cold air returns to be sealed)
7. Set-back thermostats are required.
8. When an FAU is relocated into the attic.
 - a. Structural calculations may be required for new load added to trusses, rafters and ceiling joists.
 - b. Provide combustion air and unit venting requirements per 2010 California Mechanical Code and manufacturer's specifications.
 - c. Overflow pan required under cooling coils.
 - d. CF-1R-ALT-HVAC form required to be completed at "Permit Issuance".
 - e. CF-6R form required to be completed at "Final Inspection."