

<b>Prescriptive Certificate of Compliance: Residential</b>		<b>CF-1R-ALT</b>
<b>Residential Alterations</b>		<b>(Page 1 of 5)</b>
<b>Project Name:</b>	<b>Climate Zone #</b>	<b># of Stories</b>

<b>General Information</b>		
<b>Site Address:</b>	<b>Enforcement Agency:</b>	<b>Date:</b>
Building Type <input type="checkbox"/> Single Family <input type="checkbox"/> Multi Family	Circle the Front Orientation: N, E, S, W, or degrees _____	
Conditioned Floor Area (CFA): _____	Project Type: <input type="checkbox"/> Alterations <input type="checkbox"/> Envelope <input type="checkbox"/> Fenestration <input type="checkbox"/> Roof <input type="checkbox"/> HVAC Replacement or Change Out <input type="checkbox"/> Duct Replacement <input type="checkbox"/> Water Heater	

**NOTE: This form is not to be used for Newly Constructed Buildings or Additions**

**Insulation Values For Opaque Surfaces (for Furring use the Mass and Furring Strips Construction table below)**

**Assembly Alteration**  
 **Opening of framed cavity alone** – Alterations that involve the opening of the framed cavity of a wall, ceiling, or floor must install the mandatory minimum insulation value per §150 for the altered assembly. Fill in Columns A – C and enter mandatory insulation value in Column H.  
 **Replacement of entire assembly** – Replacement of an entire wall, ceiling, or floor assembly requires the installation of Component Package- D insulation values in Table 151-C. Fill in Columns A – J.

**Opaque Surface Details For the furred portioned of Mass Walls see Furring Strips Construction Table below.**

A	B	C	D	E	F	G	H	I	J
Proposed <small>See Note</small>				Standard	Values From JA4 Table				
Tag/ ID <sup>1</sup>	Assembly Name or Type <sup>1</sup>	Framing Material and Size <sup>2</sup>	Thickness, Spacing, or Other <sup>3</sup>	U- factor <sup>4</sup>	JA4 Table Number <sup>5</sup>	Framed Cavity R-value <sup>6</sup>	Continuous Insulation R-Value <sup>7</sup>	JA4 Assembly Cell Value <sup>8</sup>	Proposed Assembly U-factor <sup>9</sup>

*Note: For furred assemblies, accounting for Continuous Insulation R-value, see Page JA4-3 and Equation 4-1. For calculating furred walls use the Mass and Furring Construction table below.*

1. For Tag/ID indicate the identification name that matches the building plans.
2. Indicate the Assembly Name or type: Roof/Ceiling, Walls, Floors, Slabs, Crawl Space, Doors and etc... Indicate the Frame type and Size: For Wood, Metal, Metal Buildings, Mass, enter 2x4, 2x6, or etc... see JA4 for other possible frame type assemblies.
3. Enter the thickness for mass in inches or Spacing between framing members enter; 16" or 24" OC; or Other for all other assembly description such as Concrete Sandwich Panel, Spandrel Panel, Logs, Straw Bale Panel and etc....
4. Based on the Climate Zone; enter the Standard U-factor from Table 151-B, C or D for each different assembly Name or type.
5. Enter the Table number that closely resembles the proposed assembly.
6. Enter the R-value that is being installed in the wall cavity or between the framing; otherwise, enter "0".
7. Enter the Continuous Insulation R-value for the proposed assembly; otherwise, enter "0".
8. Enter the row and column of the U-factor value based on Column F Table Number and enter the Assembly U-factor in Column J
9. The Proposed Assembly U-factor, Column J, must be equal to or less than the Standard U-factor in Column E to comply.

**Furring Strips Construction Table for Mass Walls Only**

A	B	C	D	E	F	G	H	I	J	K	L	M
Proposed Properties of Masonry and Concrete Walls From Reference Joint Appendix Table 4.3.5, 4.3.6, 4.3.7					Added Interior or Exterior Insulation in Furring Space from Reference Joint Appendix Table 4.3.13						Final Assembly U-factor <sup>6,7</sup>	Comment
Mass Thickness <sup>1</sup>	Assembly Name or Type <sup>2</sup>	JA4 Table Number <sup>3</sup>	JA4 -Mass Cell Value <sup>4</sup>	Mass U-Factor <sup>5</sup>	Interior or Exterior of Insulation Layer	Frame Thickness	Frame Type Wood or Metal	Furring Cavity R-value <sup>3</sup>	JA4 -Mass Cell Value <sup>4</sup>	Effective R-value <sup>5</sup>		

**Residential Lighting**

Site Address:

Enforcement Agency:

Permit Number:

**1. Kitchen Lighting**

Does project include kitchen lighting?

Yes, complete section 1     No, go on to section 2

Yes    §150(k)3: The wattage of permanently installed luminaires (lighting fixtures) has been determined as specified by §130(d).

Yes     No    §150(k)3: In the kitchen, are there electrical boxes finished with a blank cover or where no electrical equipment has been installed, and where the electrical box can be used for a luminaire or a surface mounted ceiling fan? If yes, the following row must also be yes:

Yes     NA    Wattage has been calculated as 180 watts of low efficacy lighting per blank electrical box.

**§150(k)8 Kitchen Lighting must comply with either method (a), (b), or (c) below:**

**(a) All high efficacy luminaires**

Yes, complies because only high efficacy luminaires have been installed in the kitchen.

No, complies with method (b) or (c).

**(b) ≥ 50% watts used by high efficacy luminaires**

Yes, complies because at least 50% of the installed watts are from permanently installed high efficacy luminaires as demonstrated in the table below: Total A ≥ Total B.

No, complies with method (a) or (c).

Fill out the following table if complying with either method (b) or (c).

**Table (b)**

Luminaire Type	Efficacy		Watts	x	Quantity	=	High Efficacy Watts	or	Low Efficacy Watts
	High	Low							
	<input type="checkbox"/>	<input type="checkbox"/>		x		=		or	
	<input type="checkbox"/>	<input type="checkbox"/>		x		=		or	
	<input type="checkbox"/>	<input type="checkbox"/>		x		=		or	
	<input type="checkbox"/>	<input type="checkbox"/>		x		=		or	
	<input type="checkbox"/>	<input type="checkbox"/>		x		=		or	
Complies with method (b) if $A \geq B$							Total: A:	≥	B:

**(c) Additional Kitchen Low Efficacy Lighting**

Yes, complies because the kitchen lighting qualifies for additional low efficacy lighting and as demonstrated in table in (b) (above) and the table in (c) (below) that  $(A + C) \geq B$

No, complies with method (a) or (b).

**Additional kitchen low efficacy lighting is available only if all of the following are true:**

Yes. All low efficacy luminaires in the kitchen are controlled by a vacancy sensor Dimmer energy management control system (EMCS) or a multi-scene programmable control system.

Yes. Permanently installed luminaires in garages laundry rooms closets greater than 70 square feet and utility rooms are high efficacy luminaires AND are controlled by a vacancy sensor.

**Table (c)**

From the Table in (b)		Use 50 W for dwelling units ≤ 2,500 ft <sup>2</sup> Use 100 W for dwelling units > 2,500 ft <sup>2</sup>	Add	Yes/No ?
A	B	C	A + C	Is (A+C) ≥ B ?

**2. Lighting Internal to Cabinets**

Does project includes lighting internal to cabinets?

Yes, complete section 2     No, go on to section 3

Yes, §150(k)9: Permanently installed lighting internal to cabinets uses ≤ 20 watts of power per linear foot of illuminated cabinet.

**Residential Lighting**

Site Address:

Enforcement Agency:

Permit Number:

**3. Installed Devices and Components Have Been Certified to the Energy Commission**

Does the project include any of the devices or components listed below?  Yes, complete section 3  No, go on to section 4

Yes

§119 and §150(k)7(F): Any of the following devices and components which have been installed have been certified to the Energy Commission according to the applicable provisions of §119: All LED lighting systems that are classified as high efficacy, ballasts used in recessed luminaires, vacancy sensors (automatic off/manual on occupant sensors), dimmers, track lighting integral current limiters, and outdoor motion sensors.

**4. Lighting Controls Complete section 4**

Yes  NA §150(k)7A: Permanently installed low efficacy luminaires are controlled by switches separate from those controlling high efficacy luminaires.

Yes  NA §150(k)7B: Exhaust fans with integral lighting systems are switched separately from lighting systems, OR have a lighting system that can be manually turned on and off while allowing the fan to continue to operate for an extended period of time.

Yes  NA §150(k)7C: All permanently installed luminaires are switched with readily accessible controls that permit the luminaires to be manually switched on and off.

Yes  NA §150(k)7D: All lighting controls have been installed in accordance with the manufacturer's instructions.

Yes  NA §150(k)7E: All lighting circuits that are controlled by more than one switch, where a dimmer or vacancy sensor has been installed to comply with §150(k), no controls bypass the dimmer or vacancy sensor functions.

**5. Luminaires (Lighting Fixtures)**

Does the project include the installation of any luminaires (indoor or outdoor)?

Yes, complete section 5  No, go on to section 6

Yes, high efficacy luminaire classification has been determined according to §150(k)1, and low efficacy luminaire classification has been determined according to §150(k)2.

Yes  NA §150(k)4: Fluorescent lamps rated 13 watts or greater have an electronic ballasts having an output frequency no less than 20 kHz.

Yes  NA §150(k)5: Permanently installed night lights, and night lights integral to permanently installed luminaires or exhaust fans, contain only high efficacy lamps meeting the minimum efficacies contained in Table 150-C and do not contain a line-voltage socket or line voltage lamp holder, OR the night light is rated to consume no more than 5 watts of power and does not contain a medium screw-base socket.

Yes  NA §150(k)6: Lighting integral to exhaust fans, in rooms other than kitchens, meet the applicable requirements of §150(k).

Yes  NA Any electrical box finished with a blank cover or where no electrical equipment has been installed, and where the electrical box can be used for a luminaire or a surface mounted ceiling fan, has been treated as low efficacy luminaires for compliance with §150(k).

**Does the project include any luminaires that are recessed into insulated ceilings?**

Yes, complete the rest of section 5  No, go on to section 6

Yes, §150(k)12: Luminaires that are recessed into insulated ceilings meet all of the following conditions:

Yes, are listed, as defined in §101, for zero clearance insulation contact (IC) by UL or other nationally recognized testing/rating laboratory, and

Yes, have labels that certify the luminaires are airtight with air leakage less than 2.0 CFM at 75 Pascals when tested in accordance with ASTM E283 (Exhaust fan housings are not required to be certified airtight), and

Yes, are sealed with a gasket or caulk between luminaire housings and the ceiling, and all air leak paths between conditioned and unconditioned spaces have been sealed with a gasket or caulk. (including all exhaust fan housings), and

Yes, allows ballast maintenance and replacement to be readily accessible to building occupants from below the ceiling without requiring the cutting of holes in the ceiling.

**6. Indoor Lighting (any indoor room that is not a kitchen)**

Does the project include permanently installed luminaires in any room that is not a kitchen?

Yes, complete section 6  No, go on to section 7

Yes  NA §150(k)10: Permanently installed luminaires in bathrooms, garages, laundry rooms, closets > 70 ft<sup>2</sup>, and utility rooms are high efficacy luminaires OR are controlled by a vacancy sensor.

Yes  NA §150(k)11: Permanently installed luminaires located in rooms or areas other than in kitchens, bathrooms, garages, laundry rooms, closets, and utility rooms are high efficacy luminaires, OR are controlled by a dimmer switch OR are controlled by a vacancy sensor.

**Residential Lighting**

Site Address:	Enforcement Agency:	Permit Number:
---------------	---------------------	----------------

**7. Outdoor Lighting**

Does the project include any permanently installed outdoor lighting?

<input type="checkbox"/> Yes, complete section 7 <input type="checkbox"/> No, go on to section 8	
<input type="checkbox"/> Yes <input type="checkbox"/> NA	§150(k)13: Luminaires providing outdoor lighting, including outdoor lighting for private patios on low-rise residential buildings with four or more dwelling units, entrances, balconies, and porches, and which are permanently mounted to a residential building or to other buildings on the same lot are high efficacy luminaires OR are controlled by a manual on/off switch, plus a motion sensor not having an override or bypass switch that disables the motion sensor, plus one of the following three additional control methods:
	a. A photocontrol that does not have an override or bypass switch that disables the photocontrol; or
	b. An astronomical time clock not having an override or bypass switch that disables the astronomical time clock; or
	c. Energy management controls systems (EMCS) not having an override or bypass switch that allows the luminaire to be always on.
<input type="checkbox"/> Yes <input type="checkbox"/> NA	<b>Exception 2:</b> Low efficacy outdoor luminaires used to comply with Exception 1 to §150(k)13 are controlled by an override switch which temporarily bypasses the motion sensing function, and the motion sensor is automatically reactivated within six hours. The luminaire is controlled by a photocontrol, astronomical time clock, or EMCS as required by Exception 1 to §150(k)13.
<input type="checkbox"/> Yes <input type="checkbox"/> NA	<b>Exception 3:</b> There are permanently installed luminaires in or around swimming pools, water features, or other locations subject to Article 680 of the California Electric Code which do not need to be high efficacy luminaires.
<input type="checkbox"/> Yes <input type="checkbox"/> NA	§150(k)14: Internally illuminated address signs comply with §148, OR do not contain a screw-base socket and consume no more than 5 watts of power as determined according to §130(d).
<input type="checkbox"/> Yes <input type="checkbox"/> NA	§150(k)15 Lighting for parking lots and carports with a total of 8 or more vehicles per site have lighting that complies with §130, 132, 134, and 147. Lighting for parking garages for 8 or more vehicles comply with §130, 131, 134, and 146. If yes, the Nonresidential compliance forms must be submitted

**8. Common areas of low-rise residential buildings**

Does the project include the installation of any luminaires in common areas of low-rise residential buildings?

<input type="checkbox"/> Yes, complete section 8 <input type="checkbox"/> No, go on to section 9	
<input type="checkbox"/> Yes	§150(k)16: Permanently installed lighting in the enclosed, non-dwelling spaces of low-rise residential buildings with four or more dwelling units shall be high efficacy luminaires OR are controlled by occupant sensor(s) certified to comply with §119(d).

**DECLARATION STATEMENT**

- I certify under penalty of perjury, under the laws of the State of California, the information provided on this form is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for construction, or an authorized representative of the person responsible for construction (responsible person).
- I certify that the installed features, materials, components, or manufactured devices identified on this certificate (the installation) conforms to all applicable codes and regulations, and the installation is consistent with the plans and specifications approved by the enforcement agency.
- I reviewed a copy of the Certificate of Compliance (CF-IR) form approved by the enforcement agency that identifies the specific requirements for the installation. I certify that the requirements detailed on the CF-IR that apply to the installation have been met.
- I will ensure that a completed, signed copy of this Installation Certificate shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Installation Certificate is required to be included with the documentation the builder provides to the building owner at occupancy.

Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)		
Responsible Person's Name:	Responsible Person's Signature:	
CSLB License:	Date Signed:	Position With Company (Title):

# Mandatory Measures Summary

MF-1R

Residential

(Page 1 of 3)

Site Address:

Enforcement Agency:

Date:

*NOTE: Low-rise residential buildings subject to the Standards must comply with all applicable mandatory measures listed, regardless of the compliance approach used. More stringent energy measures listed on the Certificate of Compliance (CF-1R, CF-1R-ADD, or CF-1R-ALT Form) shall supersede the items marked with an asterisk (\*) below. This Mandatory Measures Summary shall be incorporated into the permit documents and the applicable features shall be considered by all parties as minimum component performance specifications whether they are shown elsewhere in the documents or in this summary. Submit all applicable sections of the MF-1R Form with plans.*

## DESCRIPTION

### Building Envelope Measures:

§116(a)1: Doors and windows between conditioned and unconditioned spaces are manufactured to limit air leakage.

§116(a)4: Fenestration products (except field-fabricated windows) have a label listing the certified U-Factor, certified Solar Heat Gain Coefficient (SHGC), and infiltration that meets the requirements of §10-111(a).

§117: Exterior doors and windows are weather-stripped; all joints and penetrations are caulked and sealed.

§118(a): Insulation specified or installed meets Standards for Insulating Material. Indicate type and include on CF-6R Form.

§118(i): The thermal emittance and solar reflectance values of the cool roofing material meets the requirements of §118(i) when the installation of a Cool Roof is specified on the CF-1R Form.

\*§150(a): Minimum R-19 insulation in wood-frame ceiling or equivalent U-factor.

§150(b): Loose fill insulation shall conform with manufacturer's installed design labeled R-Value.

\*§150(c): Minimum R-13 insulation in wood-frame wall or equivalent U-factor.

\*§150(d): Minimum R-13 insulation in raised wood-frame floor or equivalent U-factor.

§150(f): Air retarding wrap is tested, labeled, and installed according to ASTM E1677-95(2000) when specified on the CF-1R Form.

§150(g): Mandatory Vapor barrier installed in Climate Zones 14 or 16.

§150(l): Water absorption rate for slab edge insulation material alone without facings is no greater than 0.3%; water vapor permeance rate is no greater than 2.0 perm/inch and shall be protected from physical damage and UV light deterioration.

### Fireplaces, Decorative Gas Appliances and Gas Log Measures:

§150(e)1A: Masonry or factory-built fireplaces have a closable metal or glass door covering the entire opening of the firebox.

§150(e)1B: Masonry or factory-built fireplaces have a combustion outside air intake, which is at least six square inches in area and is equipped with a readily accessible, operable, and tight-fitting damper and or a combustion-air control device.

§150(e)2: Continuous burning pilot lights and the use of indoor air for cooling a firebox jacket, when that indoor air is vented to the outside of the building, are prohibited.

### Space Conditioning, Water Heating and Plumbing System Measures:

§110-§113: HVAC equipment, water heaters, showerheads, faucets and all other regulated appliances are certified by the Energy Commission.

§113(c)5: Water heating recirculation loops serving multiple dwelling units and High-Rise residential occupancies meet the air release valve, backflow prevention, pump isolation valve, and recirculation loop connection requirements of §113(c)5.

§115: Continuously burning pilot lights are prohibited for natural gas: fan-type central furnaces, household cooking appliances (appliances with an electrical supply voltage connection with pilot lights that consume less than 150 Btu/hr are exempt), and pool and spa heaters.

§150(h): Heating and/or cooling loads are calculated in accordance with ASHRAE, SMACNA or ACCA.

§150(i): Heating systems are equipped with thermostats that meet the setback requirements of Section 112(c).

§150(j)1A: Storage gas water heaters rated with an Energy Factor no greater than the federal minimal standard are externally wrapped with insulation having an installed thermal resistance of R-12 or greater.

§150(j)1B: Unfired storage tanks, such as storage tanks or backup tanks for solar water-heating system, or other indirect hot water tanks have R-12 external insulation or R-16 internal insulation where the internal insulation R-value is indicated on the exterior of the tank.

§150(j)2: First 5 feet of hot and cold water pipes closest to water heater tank, non-recirculating systems, and entire length of recirculating sections of hot water pipes are insulated per Standards Table 150-B.

§150(j)2: Cooling system piping (suction, chilled water, or brine lines), and piping insulated between heating source and indirect hot water tank shall be insulated to Table 150-B and Equation 150-A.

§150(j)2: Pipe insulation for steam hydronic heating systems or hot water systems >15 psi, meets the requirements of Standards Table 123-A.

§150(j)3A: Insulation is protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind.

§150(j)3A: Insulation for chilled water piping and refrigerant suction lines includes a vapor retardant or is enclosed entirely in conditioned space.

# Mandatory Measures Summary

MF-1R

Residential

(Page 2 of 3)

Site Address:

Enforcement Agency:

Date:

§150(j)4: Solar water-heating systems and/or collectors are certified by the Solar Rating and Certification Corporation.

## Ducts and Fans Measures:

§150(m)1: All air-distribution system ducts and plenums installed, are sealed and insulated to meet the requirements of CMC Sections 601, 602, 603, 604, 605 and Standard 6-5; supply-air and return-air ducts and plenums are insulated to a minimum installed level of R-4.2 or enclosed entirely in conditioned space. Openings shall be sealed with mastic, tape or other duct-closure system that meets the applicable requirements of UL 181, UL 181A, or UL 181B or aerosol sealant that meets the requirements of UL 723. If mastic or tape is used to seal openings greater than 1/4 inch, the combination of mastic and either mesh or tape shall be used

§150(m)1: Building cavities, support platforms for air handlers, and plenums defined or constructed with materials other than sealed sheet metal, duct board or flexible duct shall not be used for conveying conditioned air. Building cavities and support platforms may contain ducts. Ducts installed in cavities and support platforms shall not be compressed to cause reductions in the cross-sectional area of the ducts.

§150(m)2D: Joints and seams of duct systems and their components shall not be sealed with cloth back rubber adhesive duct tapes unless such tape is used in combination with mastic and draw bands.

§150(m)7: Exhaust fan systems have back draft or automatic dampers.

§150(m)8: Gravity ventilating systems serving conditioned space have either automatic or readily accessible, manually operated dampers.

§150(m)9: Insulation shall be protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind. Cellular foam insulation shall be protected as above or painted with a coating that is water retardant and provides shielding from solar radiation that can cause degradation of the material.

§150(m)10: Flexible ducts cannot have porous inner cores.

§150(o): All dwelling units shall meet the requirements of ANSI/ASHRAE Standard 62.2-2007 Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings. Window operation is not a permissible method of providing the Whole Building Ventilation required in Section 4 of that Standard.

## Pool and Spa Heating Systems and Equipment Measures:

§114(a): Any pool or spa heating system shall be certified to have: a thermal efficiency that complies with the Appliance Efficiency Regulations; an on-off switch mounted outside of the heater; a permanent weatherproof plate or card with operating instructions; and shall not use electric resistance heating or a pilot light.

§114(b)1: Any pool or spa heating equipment shall be installed with at least 36" of pipe between filter and heater, or dedicated suction and return lines, or built-up connections for future solar heating

§114(b)2: Outdoor pools or spas that have a heat pump or gas heater shall have a cover.

§114(b)3: Pools shall have directional inlets that adequately mix the pool water, and a time switch that will allow all pumps to be set or programmed to run only during off-peak electric demand periods.

§150(p): Residential pool systems or equipment meet the pump sizing, flow rate, piping, filters, and valve requirements of §150(p).

## Residential Lighting Measures:

§150(k)1: High efficacy luminaires or LED Light Engine with Integral Heat Sink has an efficacy that is no lower than the efficacies contained in Table 150-C and is not a low efficacy luminaire as specified by §150(k)2.

§150(k)3: The wattage of permanently installed luminaires shall be determined as specified by §130(d).

§150(k)4: Ballasts for fluorescent lamps rated 13 Watts or greater shall be electronic and shall have an output frequency no less than 20 kHz.

§150(k)5: Permanently installed night lights and night lights integral to a permanently installed luminaire or exhaust fan shall contain only high efficacy lamps meeting the minimum efficacies contained in Table 150-C and shall not contain a line-voltage socket or line-voltage lamp holder; OR shall be rated to consume no more than five watts of power as determined by §130(d), and shall not contain a medium screw-base socket.

§150(k)6: Lighting integral to exhaust fans, in rooms other than kitchens, shall meet the applicable requirements of §150(k).

§150(k)7: All switching devices and controls shall meet the requirements of §150(k)7.

§150(k)8: A minimum of 50 percent of the total rated wattage of permanently installed lighting in kitchens shall be high efficacy.  
EXCEPTION: Up to 50 watts for dwelling units less than or equal to 2,500 ft<sup>2</sup> or 100 watts for dwelling units larger than 2,500 ft<sup>2</sup> may be exempt from the 50% high efficacy requirement when: all low efficacy luminaires in the kitchen are controlled by a manual on occupant sensor, dimmer, energy management system (EMCS), or a multi-scene programmable control system; and all permanently installed luminaries in garages, laundry rooms, closets greater than 70 square feet, and utility rooms are high efficacy and controlled by a manual-on occupant sensor.

§150(k)9: Permanently installed lighting that is internal to cabinets shall use no more than 20 watts of power per linear foot of illuminated cabinet.

§150(k)10: Permanently installed luminaires in bathrooms, attached and detached garages, laundry rooms, closets and utility rooms shall be high efficacy.

# Mandatory Measures Summary

MF-1R

Residential

(Page 3 of 3)

Site Address:

Enforcement Agency:

Date:

EXCEPTION 1: Permanently installed low efficacy luminaires shall be allowed provided that they are controlled by a manual-on occupant sensor certified to comply with the applicable requirements of §119.

EXCEPTION 2: Permanently installed low efficacy luminaires in closets less than 70 square feet are not required to be controlled by a manual-on occupant sensor.

§150(k)11: Permanently installed luminaires located in rooms or areas other than in kitchens, bathrooms, garages, laundry rooms, closets, and utility rooms shall be high efficacy luminaires.

EXCEPTION 1: Permanently installed low efficacy luminaires shall be allowed provided they are controlled by either a dimmer switch that complies with the applicable requirements of §119, or by a manual-on occupant sensor that complies with the applicable requirements of §119.

EXCEPTION 2: Lighting in detached storage building less than 1000 square feet located on a residential site is not required to comply with §150(k)11.

§150(k)12: Luminaires recessed into insulated ceilings shall be listed for zero clearance insulation contact (IC) by Underwriters Laboratories or other nationally recognized testing/rating laboratory; and have a label that certifies the luminaire is airtight with air leakage less than 2.0 CFM at 75 Pascals when tested in accordance with ASTM E283; and be sealed with a gasket or caulk between the luminaire housing and ceiling.

§150(k)13: Luminaires providing outdoor lighting, including lighting for private patios in low-rise residential buildings with four or more dwelling units, entrances, balconies, and porches, which are permanently mounted to a residential building or to other buildings on the same lot shall be high efficacy.

EXCEPTION 1: Permanently installed outdoor low efficacy luminaires shall be allowed provided that they are controlled by a manual on/off switch, a motion sensor not having an override or bypass switch that disables the motion sensor, and one of the following controls: a photocontrol not having an override or bypass switch that disables the photocontrol; OR an astronomical time clock not having an override or bypass switch that disables the astronomical time clock; OR an energy management control system (EMCS) not having an override or bypass switch that allows the luminaire to be always on

EXCEPTION 2: Outdoor luminaires used to comply with Exception 1 to §150(k)13 may be controlled by a temporary override switch which bypasses the motion sensing function provided that the motion sensor is automatically reactivated within six hours.

EXCEPTION 3: Permanently installed luminaires in or around swimming pool, water features, or other location subject to Article 680 of the California Electric Code need not be high efficacy luminaires.

§150(k)14: Internally illuminated address signs shall comply with Section 148; OR not contain a screw-base socket, and consume no more than five watts of power as determined according to §130(d).

§150(k)15: Lighting for parking lots and carports with a total of for 8 or more vehicles per site shall comply with the applicable requirements in Sections 130, 132, 134, and 147. Lighting for parking garages for 8 or more vehicles shall comply with the applicable requirements of Sections 130, 131, 134, and 146

§150(k)16: Permanently installed lighting in the enclosed, non-dwelling spaces of low-rise residential buildings with four or more dwelling units shall be high efficacy luminaires.

EXCEPTION: Permanently installed low efficacy luminaires shall be allowed provided that they are controlled by an occupant sensor(s) certified to comply with the applicable requirements of §119.